APEX PRECISION ANALYTICAL SERVICES, INC.
AN INDEPENDENT LABORATORY PROVIDING CONVENTIONAL AND ON-SITE ANALYSIS

PLM (Bulk) - Asbestos Analysis Report - Point Count

(EPA Method 600/M4-82-020 Point Count)

Client:
ABC Company Inc.
1234 Alpha Lane
Somewhere, Texas 77777
281-332-1111
Contact: Joe Anyone

Report Number: 0000-0000PC
Report Date: May 13, 2009
Samples Collected: April 30, 2009
Date Request Received: May 11, 2009
Turn-around time: 48 Hours

Job ID / Site: 09-3-1414 / Some Building Somewhere

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Content Type & %	Matrix
114-39	0509-1171-03C	White / Joint Compound / Fibrous / Homogeneous	Chrysotile 0.75%	None Detected	Binder
114-52	0509-1171-16A	Off White / Texture,Joint Compound / Fibrous / Homogeneous	Chrysotile 2.00%	None Detected	Binder
114-53	0509-1171-17A	White / Texture,Joint Compound / Fibrous / Homogeneous	Chrysotile 2.50%	None Detected	Binder

Laboratory Manager
Gary Simmons

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM **TDSHS Asbestos Lab License#: 30-0312 PLM/PCM**