



APEX PRECISION ANALYTICAL SERVICES, INC.

AN INDEPENDENT LABORATORY PROVIDING CONVENTIONAL AND ON-SITE ANALYSIS

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Client:
Company and Company, Inc.
111 Somewhere
Nowhere, VV 88888
555-555-5555
Contact: Joe Anyone

Report Number: 0001-0000
Report Date: April 21, 2008
Samples Collected: April 15, 2008
Date Received: April 17, 2008
Turn-around time: 72 Hours

Job ID / Site: 909090 / 123 Any Place

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
01	0008-0000-01A	Beige / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 80%	Binder
	0008-0000-01B	White / Insulation / Fibrous / Homogeneous	None Detected	Cellulose 15% Fiber Glass 5%	Binder
02	0008-0000-02	White / Insulation / Fibrous / Homogeneous	None Detected	Cellulose 15% Fiber Glass 5%	Binder
03	0008-0000-03	White / Insulation / Fibrous / Homogeneous	None Detected	Cellulose 15% Fiber Glass 5%	Binder
04	0008-0000-04	Black / Roofing Material / NonFibrous / Homogeneous	None Detected	None Detected	Binder
05	0008-0000-05	Black / Roofing Material / NonFibrous / Homogeneous	None Detected	None Detected	Binder
06	0008-0000-06	Black / Roofing Material / NonFibrous / Homogeneous	None Detected	None Detected	Binder
07	0008-0000-07	Grey,Black / Roof Flashing / Fibrous / Homogeneous	Chrysotile 6%	None Detected	Binder
08	0008-0000-08	Grey,Black / Roof Flashing / Fibrous / Homogeneous	Chrysotile 6%	None Detected	Binder
09	0008-0000-09	Grey,Black / Roof Flashing / Fibrous / Homogeneous	Chrysotile 6%	None Detected	Binder

Gary R. Simmons
Laboratory Manager

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos Lab License#: 30-0312 PLM/PCM

306 West Edgewood Dr., Suite D, Friendswood, Texas 77546 Office (281)648-9918/Fax (281)648-9595 www.apasi.net