



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

## ASBESTOS BULK ANALYSIS REPORT

Date: September 7, 2017

O'Connor Engineering & Science, Inc.

Report: 1717-3445 E. CCA-Laredo Detention Center – Lobby / 4702 Saunders St., Laredo, TX 78041

This document shall be considered a duly signed original report of the results obtained from the analysis(es) performed. All analyses are done within government guidelines and regulations.

Gary R. Simmons Laboratory Manager

Lab Comments on Project: N/A

Page 1 of 4

Apex Precision Analytical Services, Inc.



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

## PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-3445
919 Victoria Street	Report Date:	September 7, 2017
Laredo, TX 78040	Samples Collected:	September 5, 2017
956-728-1123	Date Received:	September 6, 2017
Contact: Tom O'Connor	Turn-around time:	24 Hours

Client Sample Number 1A	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity		Non-Asbestos Fibrous Type & %	Matrix
	1717-3445-01A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-01B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	1717-3445-01C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-01D	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
1B	1717-3445-02A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-02B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	1717-3445-02C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-02D	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
1C	1717-3445-03A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-03B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 2 of 4

**Apex Precision Analytical Services, Inc.** 



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

## PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-3445
919 Victoria Street	Report Date:	September 7, 2017
Laredo, TX 78040	Samples Collected:	September 5, 2017
956-728-1123	Date Received:	September 6, 2017
Contact: Tom O'Connor	Turn-around time:	24 Hours

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
1C	1717-3445-03C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-03D	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
2A	1717-3445-04A	Grey / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-04B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
2B	1717-3445-05A	Grey / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-05B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
2C	1717-3445-06A	Grey / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-06B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
ЗА	1717-3445-07	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 30% Fibrous Glass 30%	Binder
3B	1717-3445-08	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 30% Fibrous Glass 30%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 3 of 4

Apex Precision Analytical Services, Inc.



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

## PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-3445
919 Victoria Street	Report Date:	September 7, 2017
Laredo, TX 78040	Samples Collected:	September 5, 2017
956-728-1123	Date Received:	September 6, 2017
Contact: Tom O'Connor	Turn-around time:	24 Hours

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
3C	1717-3445-09	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 30% Fibrous Glass 30%	Binder
4A	1717-3445-10A	Light Blue / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-10B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
4B	1717-3445-11A	Light Blue / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-11B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
4C	1717-3445-12A	Light Blue / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-3445-12B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 4 of 4