



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

# ASBESTOS BULK ANALYSIS REPORT

Date: October 23, 2017

O'Connor Engineering & Science, Inc.

Report: 1717-4820 9902 McPherson Rd., "Laredo Salsa's" Suite #15, Laredo, TX 78045

This document shall be considered a duly signed original report of the results obtained from the analysis(es) performed. All analyses are done within government guidelines and regulations.

Gary R. Simmons Laboratory Manager

Lab Comments on Project: N/A

Page 1 of 6



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

# PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-4820
919 Victoria Street	Report Date:	October 23, 2017
Laredo, TX 78040	Samples Collected:	October 18, 2017
956-728-1123	Date Received:	October 19, 2017
Contact: Tom O'Connor	Turn-around time:	48 Hours

ob ID / Site: 9902 McPherson Rd., "Laredo Salsa's" Suite #15, Laredo, TX 78045					
Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
1A	1717-4820-01A	Red / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder
	1717-4820-01B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1B	1717-4820-02A	Red / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder
	1717-4820-02B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1C	1717-4820-03A	Red / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder
	1717-4820-03B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
2A	1717-4820-04A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder
	1717-4820-04B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
2B	1717-4820-05A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

None Detected

Yellow / Mastic / NonFibrous /

Homogeneous

NVLAP Lab Code: 200633-0 PLM

1717-4820-05B

TDSHS Asbestos License#: 30-0312 PLM/PCM

None Detected

Binder

Page 2 of 6



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

### PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-4820
919 Victoria Street	Report Date:	October 23, 2017
Laredo, TX 78040	Samples Collected:	October 18, 2017
956-728-1123	Date Received:	October 19, 2017
Contact: Tom O'Connor	Turn-around time:	48 Hours

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
2C	1717-4820-06A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 95%	Binder
	1717-4820-06B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
ЗА	1717-4820-07A	White / Wall Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-07B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	1717-4820-07C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-07D	Brown,White / Sheetrock / Fibrous / Homogeneous	None Detected	Cellulose 10%	Binder
3B	1717-4820-08A	White / Wall Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-08B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	1717-4820-08C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-08D	Brown,White / Sheetrock / Fibrous / Homogeneous	None Detected	Cellulose 10%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 3 of 6



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

# PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-4820
919 Victoria Street	Report Date:	October 23, 2017
Laredo, TX 78040	Samples Collected:	October 18, 2017
956-728-1123	Date Received:	October 19, 2017
Contact: Tom O'Connor	Turn-around time:	48 Hours

ob ID / Site: 9902 McPherson Rd., "Laredo Salsa's" Suite #15, Laredo, TX 78045				
Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
1717-4820-09A	White / Wall Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1717-4820-09B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
1717-4820-09C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1717-4820-09D	Brown,White / Sheetrock / Fibrous / Homogeneous	None Detected	Cellulose 10%	Binder
1717-4820-10	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
1717-4820-11	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
1717-4820-12	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
1717-4820-13	Brown,White / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 20%	Binder
1717-4820-14	Brown,White / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 20%	Binder
1717-4820-15	Brown,White / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 20%	Binder
	Lab Sample Number (by layer)   1717-4820-09A   1717-4820-09B   1717-4820-09C   1717-4820-09D   1717-4820-10   1717-4820-11   1717-4820-12   1717-4820-13   1717-4820-14	Lab Sample Number (by layer)Color / Description / Fibrous / NonFibrous / Homogeneity1717-4820-09AWhite / Wall Texture / NonFibrous / Homogeneous1717-4820-09BOff White / Joint Tape / Fibrous / Homogeneous1717-4820-09CWhite / Joint Compound / NonFibrous / Homogeneous1717-4820-09DBrown,White / Sheetrock / Fibrous / Homogeneous1717-4820-09DBrown,White / Sheetrock / Fibrous / Homogeneous1717-4820-10White,Grey / Ceiling Tile / Fibrous / Homogeneous1717-4820-11White,Grey / Ceiling Tile / Fibrous / Homogeneous1717-4820-12White,Grey / Ceiling Tile / Fibrous / Homogeneous1717-4820-13Brown,White / Ceiling Tile / Fibrous / Homogeneous1717-4820-14Brown,White / Ceiling Tile / Fibrous / Homogeneous1717-4820-15Brown,White / Ceiling Tile / Fibrous / Homogeneous	Lab Sample Number (by layer) Color / Description / Fibrous / NonFibrous / Homogeneity Asbestos Content Type & %   1717-4820-09A White / Wall Texture / NonFibrous / Homogeneous None Detected   1717-4820-09B Off White / Joint Tape / Fibrous / Homogeneous None Detected   1717-4820-09B Off White / Joint Compound / NonFibrous / Homogeneous None Detected   1717-4820-09C White / Joint Compound / NonFibrous / Homogeneous None Detected   1717-4820-09D Brown,White / Sheetrock / Fibrous / Homogeneous None Detected   1717-4820-09D White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-10 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-11 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-12 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-13 Brown,White / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-14 Brown,White / Ceiling Tile / Fibrous / Homogeneous None Detected   1717-4820-15 Brown,White / Ceiling Tile / Fibrous / Homogeneous None Detected	Lab Sample Number (by layer) Color / Description / Fibrous / NonFibrous / Homogeneity Asbestos Content Type & % Non-Asbestos Fibrous Type & %   1717-4820-09A White / Wall Texture / NonFibrous / Homogeneous None Detected None Detected   1717-4820-09B Off White / Joint Tape / Fibrous / Homogeneous None Detected Cellulose 95%   1717-4820-09B Off White / Joint Tape / Fibrous / Homogeneous None Detected Cellulose 95%   1717-4820-09C White / Joint Compound / NonFibrous / Homogeneous None Detected None Detected None Detected   1717-4820-09D Brown,White / Sheetrock / Fibrous / Homogeneous None Detected Cellulose 10%   1717-4820-10 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected Cellulose Fibrous Glass 45%   1717-4820-11 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected Cellulose Fibrous Glass 45%   1717-4820-12 White,Grey / Ceiling Tile / Fibrous / Homogeneous None Detected Cellulose Fibrous Glass 45%   1717-4820-13 Brown,White / Ceiling Tile / Fibrous / Homogeneous None Detected Cellulose Fibrous Glass 20%

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 4 of 6



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

# PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-4820
919 Victoria Street	Report Date:	October 23, 2017
Laredo, TX 78040	Samples Collected:	October 18, 2017
956-728-1123	Date Received:	October 19, 2017
Contact: Tom O'Connor	Turn-around time:	48 Hours

ob ID / Site: 9902 McPherson Rd., "Laredo Salsa's" Suite #15, Laredo, TX 78045					
Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
6A	1717-4820-16A	White,Silver / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 5% Fibrous Glass 10%	Binder
	1717-4820-16B	Yellow / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
6B	1717-4820-17A	White,Silver / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 5% Fibrous Glass 10%	Binder
	1717-4820-17B	Yellow / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
6C	1717-4820-18A	White,Silver / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 5% Fibrous Glass 10%	Binder
	1717-4820-18B	Yellow / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
7A	1717-4820-19A	Silver / Wrap / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-19B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
7B	1717-4820-20A	Silver / Wrap / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-20B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 5 of 6



An Independent Laboratory Providing Reliable Analysis with Professionalism and Honesty

### PLM (Bulk) - Asbestos Analysis Report - Visual ID

(EPA Method 600/R-93-116 Visual Area Estimation)

O'Connor Engineering & Science, Inc.	Report Number:	1717-4820
919 Victoria Street	Report Date:	October 23, 2017
Laredo, TX 78040	Samples Collected:	October 18, 2017
956-728-1123	Date Received:	October 19, 2017
Contact: Tom O'Connor	Turn-around time:	48 Hours

Job ID / Site: 9902 McPherson Rd., "Laredo Salsa's" Suite #15,	, Laredo, TX 78045
--	--------------------

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
7C	1717-4820-21A	Silver / Wrap / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	1717-4820-21B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
8A	1717-4820-22A	Black,Brown / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 60%	Binder
	1717-4820-22B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
8B	1717-4820-23A	Black,Brown / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 60%	Binder
	1717-4820-23B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder
8C	1717-4820-24A	Black,Brown / Mastic Wrap / Fibrous / Homogeneous	None Detected	Cellulose 60%	Binder
	1717-4820-24B	Pink / Insulation / Fibrous / Homogeneous	None Detected	Fibrous Glass 95%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only repesent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 6 of 6