

ASBESTOS BULK ANALYSIS REPORT

Date: May 7, 2020

Austin Environmental, Inc.

Report: 3420-2320
AEA20-86 / Lee Drain Building / 1900 W. Ave
I, Huntsville, TX

This document shall be considered a duly signed original report of the results obtained from the analysis(es) performed. All analyses are done within government guidelines and regulations.

A handwritten signature in black ink, appearing to read 'G.R. Simmons', written over a horizontal line.

Gary R. Simmons
Laboratory Manager

Lab Comments on Project: N/A

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Austin Environmental, Inc.
P.O. Box 143263
Austin, TX 78711
979-778-2699
Contact: Paul Dehlinger

Report Number: 3420-2320
Report Date: May 7, 2020
Samples Collected: May 5, 2020
Date Received: May 6, 2020
Turn-around time: 24 Hour

Job ID / Site: AEA20-86 / Lee Drain Building / 1900 W. Ave I, Huntsville, TX

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
1A	3420-2320-01A	Brown / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-01B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1B	3420-2320-02A	Brown / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-02B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
1C	3420-2320-03A	Brown / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-03B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
2A	3420-2320-04A	Brown / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-04B	Black / Mastic / Fibrous / Homogeneous	Chrysotile 3%	None Detected	Binder
2B	3420-2320-05A	Brown / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-05B	Black / Mastic / Fibrous / Homogeneous	Chrysotile 3%	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Austin Environmental, Inc.
P.O. Box 143263
Austin, TX 78711
979-778-2699
Contact: Paul Dehlinger

Report Number: 3420-2320
Report Date: May 7, 2020
Samples Collected: May 5, 2020
Date Received: May 6, 2020
Turn-around time: 24 Hour

Job ID / Site: AEA20-86 / Lee Drain Building / 1900 W. Ave I, Huntsville, TX

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
2C	3420-2320-06A	Brown / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-06B	Black / Mastic / Fibrous / Homogeneous	Chrysotile 3%	None Detected	Binder
3A	3420-2320-07	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
3B	3420-2320-08	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
3C	3420-2320-09	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 10%	Binder
4A	3420-2320-10A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-10B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	3420-2320-10C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-10D	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
4B	3420-2320-11A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 3 of 4

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Austin Environmental, Inc.
P.O. Box 143263
Austin, TX 78711
979-778-2699
Contact: Paul Dehlinger

Report Number: 3420-2320
Report Date: May 7, 2020
Samples Collected: May 5, 2020
Date Received: May 6, 2020
Turn-around time: 24 Hour

Job ID / Site: AEA20-86 / Lee Drain Building / 1900 W. Ave I, Huntsville, TX

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
4B	3420-2320-11B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	3420-2320-11C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	3420-2320-11D	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
4C	3420-2320-12	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.