

ASBESTOS BULK ANALYSIS REPORT

Date: July 8, 2016

Tri D Services, Inc

Report: 6516-2210
16050 / 12727 Kimberley Lane, Suite 210
Expansion

This document shall be considered a duly signed original report of the results obtained from the analyses performed. All analyses are done within government guidelines and regulations.

A handwritten signature in black ink, appearing to read 'G.R. Simmons', written over a horizontal line.

Gary R. Simmons
Laboratory Manager

Lab Comments on Project: N/A

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Tri D Services, Inc
10924 Grant Road #609
Houston, TX 77070
281-955-9990
Contact: Lance Wilkerson

Report Number: 6516-2210
Report Date: July 8, 2016
Samples Collected: July 5, 2016
Date Received: July 6, 2016
Turn-around time: 48 Hours

Job ID / Site: 16050 / 12727 Kimberley Lane, Suite 210 Expansion

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
16050-1	6516-2210-01	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 15%	Binder
16050-2	6516-2210-02	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 15%	Binder
16050-3	6516-2210-03A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-03B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-4	6516-2210-04A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-04B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-5	6516-2210-05A	White / Texture,Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-05B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	6516-2210-05C	Brown,Light Pink / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
16050-6	6516-2210-06A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 2 of 4

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Tri D Services, Inc
10924 Grant Road #609
Houston, TX 77070
281-955-9990
Contact: Lance Wilkerson

Report Number: 6516-2210
Report Date: July 8, 2016
Samples Collected: July 5, 2016
Date Received: July 6, 2016
Turn-around time: 48 Hours

Job ID / Site: 16050 / 12727 Kimberley Lane, Suite 210 Expansion

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
16050-6	6516-2210-06B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-7	6516-2210-07A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-07B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-8	6516-2210-08A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-08B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-9	6516-2210-09A	Off White / Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-09B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-10	6516-2210-10A	White / Texture, Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-10B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	6516-2210-10C	Brown, Light Pink / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 3 of 4

PLM (Bulk) - Asbestos Analysis Report - Visual ID (EPA Method 600/R-93-116 Visual Area Estimation)

Tri D Services, Inc
10924 Grant Road #609
Houston, TX 77070
281-955-9990
Contact: Lance Wilkerson

Report Number: 6516-2210
Report Date: July 8, 2016
Samples Collected: July 5, 2016
Date Received: July 6, 2016
Turn-around time: 48 Hours

Job ID / Site: 16050 / 12727 Kimberley Lane, Suite 210 Expansion

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
16050-11	6516-2210-11	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-12	6516-2210-12	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-13	6516-2210-13	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16050-14	6516-2210-14A	White / Texture,Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6516-2210-14B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	6516-2210-14C	Brown,White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
16050-15	6516-2210-15	White,Grey / Ceiling Tile / Fibrous / Homogeneous	None Detected	Cellulose 45% Fibrous Glass 15%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

NVLAP Lab Code: 200633-0 PLM

TDSHS Asbestos License#: 30-0312 PLM/PCM

Page 4 of 4